

357 Southwind Cir.  
Abilene Texas 79602  
PH: 325-672-0793 e-mail: jrose@bradshawengineer.com  
Cell:325-201-2929

**Bradshaw &  
Associates - MEP  
Engineering**

**Transmittal**

**To:** **From:** Johnny L. Rose

**WCTMWD**

**Fax:** 325-673-8272

**Pages:** 1

**Phone:** 325-673-8254

**Date:** 1/8/18

**Re:** W.C.T.M.W.D. 2017 HVAC PROJECT **CC:** \*

**Urgent**     **For Review**     **Please Comment**     **Please Reply**     **Please Recycle**

● **Comments:**

The attached items need to be added as an Addendum 1 to the 2017 HVAC RENOVATIONS W.C.T.M.W.D. project. Call or e-mail if you have any questions.

Specs Section 00010 – 11 of 41:

1. Table "A", No DDC controls will be required on this project. Each unit shall be controlled with programmable thermostat.

Specs Section 01010 – 1 of 2:

2. A: Base Bid: The entire project shall be completed by March 30<sup>th</sup>, 2018

Mechanical Demolition Plan Sheet DM1.1 & DM1.2, Note 1:

3. After removal of existing zone control thermostat, mechanical contractor shall install blank cover plate to cover wall opening.

Johnny L. Rose  
Project Manager  
Bradshaw & Associates-Engineering